

Start-Work Checks

Energized / Live Electrical Work



Start-Work Authority: Confirm below are in place and verified prior to starting work

Save Your Life Actions All exposed persons performing work must confirm each action below.	Person(s) Performing Work (initial)	Start-Work Verifier (initial)
I have confirmed:		
1 The authorized work scope has been reviewed and agreed to.		
2 Personnel are wearing PPE rated for: <ul style="list-style-type: none"> a. The arc flash per the arc flash hazard analysis. b. The electrical voltage prior to entering the limited approach boundary. 		
3 Circuit/equipment to be worked on is the one identified in the plan.		
4 Safe work zones have been identified and visually barricaded.		
5 Electrical standby person has been assigned and emergency response plan has been agreed to.		
6 Communication plan with the standby person has been agreed to, including stop work signals.		
7 Insulated tools and testing equipment have been inspected for damage and are rated for the task.		

Stop and seek help if any of the above safeguards are not in place

Work Permit No.: _____

Role	Printed Name	Date
Start-Work Verifier		

Start-Work Checks Energized / Live Electrical Work

