



Hot Work CoW Standard Designated Safe Hot Work Area Assessment

The objective of designated safe hot work areas is to define a temporary or permanent area in which open flame hot work can safely be conducted in a manner that mitigates all risks associated with fires and flammable atmospheres. As per the Hot Work Control of Work Technical Standard, the designated safe hot work area shall be assessed initially upon construction and shall be reassessed when conditions change OR every one year with approval by the Division Superintendent or Team Leader. Records of the most recent assessment shall be kept with the division and associated contractor.

Date of Assessment:	
----------------------------	--

Requirement	Hot Work Team / Contractor Initial	JO Supervisor Initial
Located outside of a Hazardous (Classified) area.		
Safe Hot Work Area is clearly identified and communicated.		
Constructed of non-combustible or fire-resistant construction or adequately guarded or protected.		
Maintained free of flammable and combustible materials OR such materials shall be adequately guarded or protected.		

X

Welding Team Representative

X

Division TL / Supt.